



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
DY3323	5.6	Upright	SR	5 mm	1/2	Brass	135, 155, 175 (57, 68, 79)
DY3329	5.6	Horizontal Sidewall	SR	5 mm	1/2	Polyester	135, 155, 175 (57, 68, 79)
DY3423	5.6	Upright	QR	3 mm	1/2	Brass	155 (68)
DY3429	5.6	Horizontal Sidewall	QR	3 mm	1/2	Polyester	155 (68)

Prepared for: Duyar Vana Makina San. Tic. ve A.Ş, Uğur Mumcu Mah. 2347 Sk.  
No: 7, Sultangazi, İstanbul 34265, Turkey

Manufacturing Location: Duyar Vana Makina San. Tic. ve A.Ş, Ferhatpaşa Mah. 39 Sok. No:  
16 A/S, Ataşehir, İstanbul 34888, Turkey

FM Approvals Class: 2016, 2012  
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3059454

Approval Granted: October 19, 2018

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA